

REPORT OF EXAMINATIONS
Routing Slip

File No. 62-27557

	<u>Initial</u>	<u>Date</u>
Author	<u>LAW</u>	<u>1/25/92</u>
Tracking	_____	_____
Typist	<u>Deb</u>	<u>1-27-92</u>
Proofed by Typist	_____	_____
Checked by Reviewer (1)	_____	_____
Checked by Reviewer (2)	_____	_____
Proofed by Author	<u>LAW</u>	<u>1/27/92</u>
Author's Signature	<u>LAW</u>	<u>1/27/92</u>
Lead Permit Writer Approval	_____	_____
Section Supervisor Approval and Signature	<u>gb.</u>	<u>1/27/92</u>

Mail Copies of Report to:

- 1) Fisheries ☒ _____
- _____
- 2) Wildlife ☒ Hal Beecher
- _____
- 3) Tribal _____
- _____
- 4) Protestant (s) _____
- _____
- 5) Dept. of Health ☒ _____
- _____
- 6) Others ☒ Gary Hanson
- _____

Enclosures:

- 1) Interim Guidelines _____
- 2) Wac's 508-64 (Meter)
- 3) GW Bulletin #1 _____
- 4) Others _____

Attach MOK

Mail Originals and cc's _____

(S)

CHRISTINE O. GREGOIRE
Director



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

7272 Cleanwater Lane, LU-11 • Olympia, Washington 98504-6811 • (206) 753-2353

August 1, 1990

Mr. Steve Prather
Clark Public Utilities
Post Office Box 8900
Vancouver, Washington 98668

Re: Ground Water Application No. G2-27557

Dear Mr. Prather:

On July 5, 1990, you requested an extension of the July 12, 1989 temporary permit issued under the above application, to operate Well No. 109. Provision #3 of that temporary permit stated that you must perform weekly water level monitoring of Well No. 109 and the "Thomas Well," and plot the results in hydrograph form. Prior to granting this extension, our office will need to evaluate the results and analysis of that monitoring to ensure there are no detrimental effects from pumping this well. As soon as we receive your findings we will issue our determination on your extension.

You also requested an approximate schedule for Ecology's further action on the regular permit for this well. Before we take action or issue findings on this or any other current Clark Public Utilities application, we will need to receive the hydrology data previously requested by our hydrogeologist, Kirk Sinclair. Please provide:

- 1) all available static water level measurements for your entire system; and
- 2) all available monthly and yearly water use statistics for your service area.

Please submit the above data in spreadsheet format on floppy disks. We will be happy to supply blank disks at your request. Once we receive the information, we estimate it will take at least two months for review and issuance of our determination.

Any new permit issued to Clark Public Utilities will be conditioned on implementation of a conservation plan approved by Ecology. The standards for such a plan will be circulated shortly by the Departments of Health and Ecology.

We understand the importance of an adequate water supply for your service area. We are confident that ways can be found to meet this need under the principles of sound resource management.

S

Mr. Steve Prather
August 1, 1990
Page 2

Please feel free to contact me at (206) 753-2977 if you have any further questions.

Sincerely,

Gale Blomstrom

Gale Blomstrom
Water Resources Supervisor
Southwest Regional Office

GB:law

cc: Kirk Sinclair

S

Clark Public Utilities



A customer-owned public utility district

July 5, 1990

Department of Ecology
S.W. Regional Office
7272 Cleanwater Lane LV11
Olympia, WA 98504-6811

ATTENTION: GALE BLOMSTROM

RE: G.W. Appl. No. 62-27557

Dear Ms. Blomstrom:

Your records will show that the temporary permit issued under the above application expires on July 11, 1990. We still desire a regular permit on this well and would appreciate being advised of an approximate schedule for further action by Ecology.

Pending the issuance of a permanent permit we do request an extension of the temporary permit.

We have retained Pacific Groundwater Group of Seattle to do an analysis of the relationship between our well and the Thomas well. Upon completion of their work, we will advise you of the findings.

Thank you for your consideration of this request for extension of the temporary permit.

Sincerely,

Steve Prather

S

CHRISTINE O. GREGOIRE
Director



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

7272 Cleanwater Lane, LU-11 • Olympia, Washington 98504-6811 • (206) 753-2353

July 12, 1989

Debbie L. Van Scotter
Water Data Coordinator
Clark County PUD
P.O. Box C-005
Vancouver, Washington 98668

Dear Ms. Van Scotter:

Ground Water Application Number G 2-27557

On June 14, 1989, you requested a temporary permit to operate well number 109 (the Achen well) at 300 gallons per minute (gpm) pending our formal decision on your application.

Under the provisions of Chapters 90.03.250 and 90.44.020 Revised Code of Washington, the Department of Ecology may issue a temporary permit to enable an applicant to obtain the necessary information to assess the potential impact(s) of a proposed ground water withdrawal. This letter serves as a temporary permit to operate well number 109. This temporary permit is issued subject to the following conditions:

1. The priority date of this temporary permit is August 26, 1986.
2. This temporary permit is pertinent only to well number 109. The instantaneous withdrawal from this well shall not exceed 300 gpm.
3. The water level in well number 109 and the "Thomas Well" shall be monitored at least weekly during the operation of well number 109. The water level information shall be plotted in hydrograph form, and any abnormal decrease in water level shall immediately be reported to Ecology.
4. This temporary permit expires on July 11, 1990.
5. In issuing this temporary permit, Ecology in no way guarantees that a formal permit for this withdrawal will be granted.

Sincerely,

Gary E. Hanson
Water Resource Supervisor

S

GH:ks(3)
cc: Kirk Sinclair

CHRISTINE O. GREGOIRE
Director



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

7272 Cleanwater Lane, LU-11 • Olympia, Washington 98504-6811 • (206) 753-2353

July 12, 1989

Debbie L. Van Scotter
Water Data Coordinator
Clark County FUD
P.O. Box C-005
Vancouver, Washington 98668

Dear Ms. Van Scotter:

Ground Water Application Number G 2-27557

On June 14, 1989, you requested a temporary permit to operate well number 109 (the Achen well) at 300 gallons per minute (gpm) pending our formal decision on your application.

Under the provisions of Chapters 90.03.250 and 90.44.020 Revised Code of Washington, the Department of Ecology may issue a temporary permit to enable an applicant to obtain the necessary information to assess the potential impact(s) of a proposed ground water withdrawal. This letter serves as a temporary permit to operate well number 109. This temporary permit is issued subject to the following conditions:

1. The priority date of this temporary permit is August 26, 1986.
2. This temporary permit is pertinent only to well number 109. The instantaneous withdrawal from this well shall not exceed 300 gpm.
3. The water level in well number 109 and the "Thomas Well" shall be monitored at least weekly during the operation of well number 109. The water level information shall be plotted in hydrograph form, and any abnormal decrease in water level shall immediately be reported to Ecology.
4. This temporary permit expires on July 11, 1990.
5. In issuing this temporary permit, Ecology in no way guarantees that a formal permit for this withdrawal will be granted.

Sincerely,

A handwritten signature in cursive script, reading "Gary E. Hanson".

Gary E. Hanson
Water Resource Supervisor

GH:ks(3)
cc: Kirk Sinclair

(S)



"A consumer-owned electric and water utility, established 1938."

Public Utility District of Clark County

P. O. Box C-005 • Vancouver, Washington 98668
(206) 699-3000 • Toll Free in Washington 1-800-562-1736

W. Bruce Bosch
Chief Executive Officer/General Manager

Board of Commissioners
Carol Curtis-Somppi, District 1
Paul Runyan, District 2
Jane Van Dyke, District 3

June 14, 1989

Kirk Sinclair
Department of Ecology
7272 Cleanwater Lane, LU-11
Olympia, WA 98504-6811

Dear Mr. Sinclair:

Subject: Ground Water Application No. G2-27557

I am requesting that a temporary permit for 300 gpm be issued to operate Well #109. A temporary permit is necessary to perform the aquifer test that the Department of Ecology is requesting.

Enclosed is the "Thomas Well (603) Test Report" prepared by Carr & Associates on October 21, 1988. Also included, are draw down readings taken at Thomas' well by Clark Public Utilities since February of this year. Hopefully, this will clarify any concerns about interference between pumping Well #109 and the Thomas well.

I spoke to Doug Dow of Carr and Associates and it is my understanding that Clark Public Utilities has performed the necessary tests for drilling a production well. This data is included in the "Achen Well (109) Test Report" which I sent to you on May 22, 1989 along with the ground water application.

Please specifically outline the necessary steps Clark Public Utilities needs to take to secure the water right claim. If you have any questions or need additional information, please contact me at (206) 699-3261 or Doug Dow of Carr and Associates at (206) 851-5562.

Sincerely,

Debbie L. Van Scotter

Debbie L. Van Scotter
Water Data Coordinator

(S)
** (see Clark Co. GW info. file)*

Recd
9-2-89
SF

Affidavit of Publication

STATE OF WASHINGTON)

County of Clark)

SS.

Joanne Cox being first duly sworn on oath, deposes and says: That she is the Principal Clerk of THE COLUMBIAN, a legal newspaper published in Clark County, Washington and approved by the Superior Court of Clark County, Washington. That the annexed is a true copy of a

NOTICE OF APPLICATION

as it was published on:

the 14 day of June, 19 89.

the 21 day of June, 19 89.

the _____ day of _____, 19 ____.

the _____ day of _____, 19 ____.

the _____ day of _____, 19 ____.

the _____ day of _____, 19 ____.

That the fee charge for the publication is the sum of

\$ 44.40.

Joanne Cox (S)

Subscribed and sworn to before me

this 7 day of July, 19 89.

Shirley Butz

NOTARY PUBLIC in and for the
State of Washington
Residing in Vancouver.

4900-019

JO
OF WASHINGTON
MENT OF ECOLOGY
E OF APPLICATION
D APPROPRIATE
PUBLIC WATERS

TAKE NOTICE:
That Clark Public Utility of Vancouver, Washington on May 22, 1989 under Application N. G2-27557 filed for permit to appropriate public waters, subject to existing rights, from a well in the amount of 300 gallons per minute year round as needed each year, for municipal supply.

The source of the proposed appropriation is located within NW¼ NE¼ of Section 29, Township 4 N., Range 3 E.W.M., in Clark County.

This application is subject to Chapter 173-592 WAC, Reservation of Future Public Water Supply for Clark County, effective August 13, 1986.

Protest or objections to approval of this application must include a detailed statement of the basis for objections; protests must be accompanied by a two dollar (\$2.00) recording fee and filed with the Department of Ecology, at the address shown below, within thirty (30) days from June 21.

Department of Ecology
7272 Cleanwater Lane MS/LU11
Olympia, WA 98504
June 14, 21

affidavit OK
90-2-89
SF

CHRISTINE O. GREGOIRE
Director



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

7272 Cleanwater Lane, LU-11 • Olympia, Washington 98504-6811 • (206) 753-2353

June 6, 1989

Clark Public Utilities
P.O. Box 8900
Vancouver, WA 98668

Dear Gentlemen:

Ground Water Application No. G 2-27557

Your application for the appropriation of water has been assigned the above-referenced number. Please refer to this number in future correspondence.

Enclosed is a notice of your application which must be published once a week for two consecutive weeks in a qualified legal newspaper of general circulation in Clark County. A list of these newspapers in your county is enclosed.

Please read the notice carefully to make sure it is correct. Should you find an error, please return the notice to our office for correction.

You should mail or deliver the enclosed Notice to a newspaper regarding publication as soon as possible. When you receive the affidavit of publication with newsclipping from the newspaper, please forward the original to us promptly. This will shorten the time for further processing of your application.

Since your application is for service of more than one residence, it is considered a public water supply. Public water supply systems are required to be approved by either the local health department or the Department of Social and Health Services (DSHS) depending upon system size. If you have not already done so, we suggest that you contact either your local health department or DSHS, Water Supply and Waste Section, Mail Stop ID-11, Olympia, Washington 98504 for further information.

Sincerely,

Vicki Windust

Vicki Windust
Resource Management
SOUTHWEST REGIONAL OFFICE

VW:dr
Enclosure
cc: DSHS, Water Supply and Waste Section
ECY 040-1-104
Rev. 11-82

S

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

NOTICE OF APPLICATION TO APPROPRIATE PUBLIC WATERS

TAKE NOTICE:

That Clark Public Utility
of Vancouver, Washington on May 22, 1989 under
Application No. G 2-27557 filed for permit to appropriate public waters, subject to existing rights,
from a well
in the amount of 300 gallons per minute year round as needed
each year, for municipal supply.

The source of the proposed appropriation is located within NW $\frac{1}{4}$ NE $\frac{1}{4}$

of Section 29, Township 4 N., Range 3 E W.M., in Clark County.

This application is subject to Chapter 173-592 WAC, Reservation of Future Public Water Supply for Clark County, effective August 13, 1986.

Protests or objections to approval of this application must include a detailed statement of the basis for objections; protests must be accompanied by a two dollar (\$2.00) recording fee and filed with the Department of Ecology, at the address shown below, within thirty (30) days from

(Last date of publication to be entered above by publisher)

* Notice is to be published once a week for two consecutive weeks

S